



Tierra Del Sol Industrial Park - 2329 Lava Lane
P.O. Box 642, Alamosa, CO 81101
Tel: 719-589-1024 Fax: 719-589-3697
E - Mail Address: juliez@sangrelabs.com
www.sdclaboratory.com

Standard Bacteriological Water Test

Date Collected: 3/29/2022 Email: composttech@gmail.com
System Name: Compost Technologies
Mailing Address: 48414 CR B, Center, CO 81125
Time Collected: 11:00 County: Saguache
Contact Person: Mark Inness Water System Type: Private Well
Telephone Number: 719-588-8950 Collected By: Mark Inness
Sample Location: **51201 CR G, Center CO @ over head**

Laboratory Information

Lab Sample Number: 44090P
Date Received: 3/29/2022 Analysis Date: 3/30/2022

Parameter	Results MPN/100 mL	MRL MPN/100 mL	Method
Coliform, Total (Verified)	< 1.0	1.0	SM 9223B
<i>E. coli</i> (Verified)	< 1.0	1.0	SM 9223B

* Residual Chlorine Value Provided By Client

Absent / <1.0 = Compliance with drinking water standards. Absence of Coliform bacteria.

MPN / 100 mL = Most Probable Number per 100 milliliters

MRL = Method Reporting Limit

Reviewed & Approved By:

L. Shriber de Cuevas

Date: 3/31/2022
